


SCV Water

Groundwater Well Maintenance (a deep subject)

Groundwater Wells

- Alluvial Wells
 - Depth 116' 310'
 - 36 "active" domestic
- Saugus Wells
 - Depth 1,120' 2,130'
 - 9 "active" domestic
- Other wells
 - 8 "inactive", standby and non-potable





Routine Above Ground Maintenance

- Reading
 - Flow rates, production, pressures, disinfection dosages
- Listening
 - Motors, pumps, valves
- Sampling
 - Ensuring water quality compliance
- Physical
 - Adjusting and replacing mechanical equipment





Below Ground Maintenance



